



REVISIONS				
ZONE	REV	DESCRIPTION	DATE	APPROVED
	A	UPDATED-NO CHANGE	05/15/2000	B. RABBITT

- NOTES:
1. FRAME FINISH GOLD IRRIDITE PER. MIL-C-5441
 2. WELD PER A8381
 3. PRESSURE TEST 150 PSI N2 UNDER WATER
 4. BRIGHTEN FINS PRIOR TO FRAME ASS'Y PER. TEP 101-06
 5. INTERNAL FLUSH AND TUBE TREAT PER. TEP 101-07
 6. APPLY LABEL AS SHOWN , MARK DATE CODE

CONFIDENTIAL INFORMATION	DRAWN BY: J. RUBITSKI	DATE: 05/15/2000	THERMATRON ENGINEERING Inc. 687 LOWELL STREET, METHUEN MA 01844 * PHONE: (978)-687-8844 FAX: (978)-687-8844 E-MAIL: RFP@THERMATRONENGL.COM * Web Site: HTTP://WWW.THERMATRONENGL.COM
	CHECKED BY: B. RABBITT	DATE: 05/15/2000	
	APPROVED BY: B. RABBITT	DATE: 05/15/2000	TITLE: HEAT EXCHANGER
	THIS DRAWING CONTAINS RESTRICTED INFORMATION THAT IS RESTRICTED. USE OF THE INFORMATION CONTAINED HEREIN WITHOUT THE EXPRESS CONSENT OF THERMATRON ENGINEERING IS STRICTLY PROHIBITED.	MATERIAL: CU FIN, 316L TUBE FINISH: SEE NOTES	UNLESS OTHERWISE SPECIFIED, DIMENSIONS ARE IN INCHES.
REFERENCE No.	TOLERANCE	DECIMALS: .XX ± 0.015 .XXX ± 0.010 ANGLES: ± 1/2	THIRD ANGLE PROJECTION
NEXT ASSEMBLY:			SCALE: 1:1 SHEET: 1 OF 1