



REVISIONS				
ZONE	REV	DESCRIPTION	DATE	APPROVED
	A	RELEASED	01/28/2002	R. LOPEZ

- NOTES:
- ▲ WELD PER A8381
  - ▲ PRESSURE TEST 150 PSI N2 UNDER WATER
  - ▲ BRIGHTEN FINS PRIOR TO FRAME ASS'Y PER. TEP 101-06
  - ▲ INTERNAL FLUSH AND TUBE TREAT PER. TEP 101-07

<b>CONFIDENTIAL INFORMATION</b>	DRAWN BY: S. RABBITT	DATE: 01/28/2002	<b>THERMATRON ENGINEERING Inc.</b> 687 LOWELL STREET, METHUEN MA 01844 * PHONE: (978)-687-8844 FAX: (978)-687-8844 E-MAIL: RFP@THERMATRONENG.COM * Web Site: HTTP://WWW.THERMATRONENG.COM
	CHECKED BY: D. SAVOY	DATE: 01/28/2002	
	APPROVED BY: S. RABBITT	DATE: 01/28/2002	
THIS DRAWING CONTAINS INFORMATION THAT IS RESTRICTED. USE OF THE INFORMATION CONTAINED HEREIN WITHOUT THE EXPRESS CONSENT OF THERMATRON ENGINEERING IS STRICTLY PROHIBITED.	MATERIAL: CU FIN, STAINLESS TUBE FINISH.	TITLE: HEAT EXCHANGER	
REFERENCE No.	UNLESS OTHERWISE SPECIFIED, DIMENSIONS ARE IN INCHES.	CODE INDENT. No. 1GQ06	DRAWING No. 732SPP2
NEXT ASSEMBLY:	TOLERANCE DECIMALS: .XX ± 0.015 .XXX ± 0.010 ANGLES:     ± 1/2	THIRD ANGLE PROJECTION	DRAWING SIZE: <b>C</b>
		SCALE: 1:1	SHEET: 1 OF 1